



Approval of the Trademark Trevira CS®

PUGI R. G. S.r.l.
Via Garibaldi 33 b
51037 Montale (PT)
Italy

Application No.:	230743
Date of issue:	26.09.2023
Valid until:	26.09.2028
Article name:	NEMI L
End use:	Drapes Curtains Transport sector Wall coverings
Square weight (g/m²):	240
According to customer specification	
Composition of the raw materials:	Polyester 100%
Composition of the fabric:	Trevira CS 100%

The tested article NEMI L col black with application no. 230743 is granted approval for the trademark Trevira CS® for interior use.

This article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

The article meets the requirements for class 1 according to EN 13773.

DIN EN ISO 6940/6941: For Trevira CS fabrics no ignition and no rate of flame spread is measured.

This article can also meet the requirements for the fire index BKZ 5.3 (BKZ = fire index, combustibility 5 = flame retardant, level of smoke emission 3 = low smoke emission) according to the Swiss standard SN 198898.

Trevira CS fabrics also meet the requirements according to the North American NFPA Life Safety Code 101, class A, Test Standard ASTM E84 Surface Burning Characteristics, Test Report No. 12-002-527, dated August 30, 2012.

This article can meet the requirements according to FAR/JAR/CS 25.853 App. F to part 25, part I, § (a), (1) (ii) (vertical test, ignition time 12 sec).

Indorama Ventures Fibers Germany GmbH
(This document is valid without signature.)